PART 3 of 3 - HAZARDOUS AREA COMPLETION CERTIFICATE- ELECTRICAL ELECTRICAL INSPECTOR TO COMPLETE THIS SHEET

Insert Company Logo

Certificate I	no.
---------------	-----

New System: Decide Modification, Extension or Alteration to Existing System: Decide (tick appropriate box)

Extent of system covered by this certificate	Address	6:		
Certificate of compliance to I.S. 10101	Yes / No or N/A	Initial	Note No.s	Document Reference No. & Revision
/erification Dossier complete, see ATEX verification guide for details				
Test Record Sheets				
Cable schedules				
TEX Register in place and populated with all technical data.				
S. EN 62305 Lightning/Surge Protection certificate				
Detailed initial inspection complete and any outstanding actions recorded.				
escriptive Systems Document.				
lazardous Area Classification (HAC) drawings.				
ixplosion Protection Document (EPD) and related documentation.				
The installed equipment and assemblies align with the issued design documentation, have been supplied with the required documentation and are marked suitable for the				
cone of use as advised by the Person responsible for electrical design.				
All equipment has been installed in accordance with the manufacturer's instruction.				
Il equipment ATEX certificates reviewed. All special conditions of the equipment				
ertification have implemented as per the manufacturer / designer(s) instructions.				
The Electrical, Control & instrumentation installation work covered by this certificate to he best of my knowledge and belief in accordance with standard I.S. EN 60079-14.				
/ariable Speed drive systems				
TEX related Functional safety documentation				
Il electrical equipment has been installed in accordance with the issued design ocumentation.				
Suide: . List Notes in the box provided below for all notes referenced in boxes above. . Provide drawing numbers or drawing index number in the document reference section				
Notes:				
Electrical Insp	ector(s) Details			
I/We, being the person(s) responsible for the INSPECTION of the electrical installation in a h above, having exercised reasonable skill and care when carrying out the INSPECTION, here best of our knowledge and belief, in accordance with relevant standards, HSA ATEX Deliver above (attach an additional sheets if required)	eby certify that the refe	erenced work in	this report for whic	h we have been responsible is, to the
Responsible Person's Name:		Position:		
Competence:	Affiliation (CEng / Other):			
Signature:	Date	ə:		
for and behalf of				
for and behalf of:				